

**CROSS CONNECTION SURVEY
PLUMBING SYSTEM**

Date of Survey: (YYYY/MM/DD)



Township of Centre Wellington
7444 County Rd 21
Elora, On N0B 1S0
Tel: 519-846-9801 Fax: 519-846-9858

APPENDIX "B"

Does Building have a Fire Protection System? <input type="checkbox"/> Yes or <input type="checkbox"/> No	Chemical addition to Fire System? <input type="checkbox"/> Yes or <input type="checkbox"/> No	Fire System Existing Protection Device:	Fire System Date of Last Test: (YYYY/MM/DD)	Page #
---	--	---	--	--------

Facility or Business Name:	Address:	Note: Survey report to be given to: <input type="checkbox"/> Township and <input type="checkbox"/> Owner	
Owner:	Phone number: Email Address:		
Plumbing Company:	Surveyor:	OWWA Certification #	Phone #:

	Location of Cross-Connection	Degree of Hazard <i>Mild/Moderate/ Severe</i>	Existing Protection Type	Serial Number	Date of Last Test (YYYY/MM/DD)	Acceptable Protection Yes or No	Required Upgrade	Remarks:
	PREMISE							
	PREMISE							
1								
2								
3								
4								
5								
6								
7								
8								

DCAP - Dual check valve type with atmospheric port LFVB - Laboratory faucet type vacuum breaker HCVB - Hose connection type vacuum breaker	DCVA -Double check valve assembly RP -Reduced pressure principal type DUC -Double check valve type	LACV -Listed alarm check valve AG -Air Gap RSCV -Resilient seated check valve N -None	RPDA -Reduced pressure detector assembly DCDA -Double check detector assembly AVB -Atmospheric type vacuum breaker PVB -Pressure type vacuum breaker
---	---	--	---

Backflow devices are to be selected and installed for premise, zone and source isolation in accordance with the Township of Centre Wellington By-Law No 2006-080 Section 8, the Ontario Building Code and CSA Standard- B64.10-11

FULL DISCLOSURE REQUIRED: This form is intended to assist the Qualified Person in carrying out a survey. It is the responsibility of the owner or building occupant to bring to the attention of the Qualified Person all water uses within the premises. It is the responsibility of the Qualified Person to inspect and report **all** potential cross connections.